

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-0257:107

Page 1 of 1

**CATEGORY:** System Smoke Detectors/Ionization

**LISTEE:** Yale, 1902 Airport Rd., Monroe, NC 28110  
Contact: \*Jeff Trull (704) 283-2101

**DESIGN:** Models MPD-I and PTD-II. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as ionization smoke detectors for use with separately listed compatible control units. Model MPD-I is intended for use with Model 4200 series door holder/closer (CSFM Listing No. 3550-0257:105). Model PTD-II is intended for use with Models 400 series or 3000 series door holder/closer (CSFM Listing No. 3550-0257:105).

**NOTE:** Formerly 7256-0257:107

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**